

ADA Transition Plan

City of Sparta, TN

November 2019

Revised October 2022



Note: This is a living document, updated and refreshed as changes occur.

Introduction

The Americans with Disabilities Act (ADA) is a wide-ranging civil rights law that prohibits discrimination against people with disabilities in employment, transportation, public accommodation, communications, and governmental activities. It is a law that was enacted by the U. S. Congress in 1990. It was signed into law on July 26, 1990, by President George H. W. Bush. On July 23, 2010, Attorney General Eric Holder signed final regulations revising the Department's ADA regulations, including its ADA Standards for Accessible Design. These final rules went into effect on March 15, 2011, but were not required until March 15, 2012. There are five (5) separate Titles (or sections) of the Americans with Disabilities Act (hereafter referred to as "ADA") as follows:

Title I – Employment

Title II – Public Services and Transportation

Title III – Public Accommodations

Title IV – Telecommunications

Title V – Miscellaneous

Pursuant to Title II of the ADA, public entities are prohibited from discriminating on the basis of a disability. All programs, services and activities offered by the public entity must be accessible to persons with disabilities. In order to accomplish this, the Department of Justice developed regulations requiring the City to conduct a Self-Evaluation of the accessibility of its programs and services to determine whether issues of accessibility could be addressed through changes in the way such programs and services are provided.

The City is obligated to remove physical barriers to accessibility when program changes cannot ensure access to services, programs, and activities in existing facilities. Realizing that the structural changes would take time and money to provide, the Department of Justice Regulations, Federal Register 28 CFR Part 35, states that "in the event that structural changes to facilities will be undertaken to achieve program accessibility, a public entity that employs 50 or more persons shall develop a Transition Plan setting forth the steps necessary to complete such changes." Additionally, "if a public entity has responsibility or authority over streets, roads, or walkways, its Transition Plan shall include a schedule for providing curb ramps or other sloped areas where pedestrian walks cross curbs, giving priority to walkways serving entities covered by the Act."

The law also reads that:

"(a) A public entity" (without qualifying by number of employees or any other measurement) "shall, within one year of the effective date of this part, evaluate its current services, policies, and practices, and the effects thereof, that do not or may not meet the requirements of this part and, to the extent modification of any such services, policies, and practices is required, the public entity shall proceed to make the necessary modifications.

(b) A public entity shall provide an opportunity to interested persons, including individuals with disabilities or organizations representing individuals with disabilities, to participate in the Self-Evaluation process by submitting comments."

At a minimum, a Transition Plan must:

1. Identify an ADA Coordinator
2. Identify Barriers to Access
 - a. Within the Public Right-of-Way - Priorities for areas of Town:
 - State and local government offices
 - Places of public accommodation (parks, schools, Depot Square, etc.)
 - Other areas of Town (older residential neighborhoods)
 - b. To Town-owned facilities
 - Develop list of Town-owned facilities
 - List those facilities that are used by the public
 - Assess from parking lot to inside the building (meeting rooms, restrooms, etc.)
 - c. To Town programs, services and activities
 - Board meetings
 - Public meetings
 - Communication
3. Develop a Complaint Process
4. Develop/Adopt Design Standards
5. Identify Public Involvement Opportunities
6. Identify Plan (time and budget) to Remove Barriers
7. Reevaluation Schedule

Public Notice

**CITY OF SPARTA
NOTICE
The Americans with Disabilities Act**



The City of Sparta does not discriminate on the basis of disability in admission to, access to, or operations of its programs, services, or activities. The City of Sparta does not discriminate on the basis of disability in its hiring or employment practices.

(This notice is provided as required by Title II of the Americans with Disabilities Act of 1990.)

Questions, concerns, complaints, or request for additional information regarding the ADA/504 may be forwarded to the City of Sparta:

Daniel Marcum
ADA Coordinator, City of Sparta
6 Liberty Square, Sparta, TN 38583
Phone: 931-836-3248
d.marcum@spartatn.gov

Individuals who need auxiliary aids for effective communication in programs or services of the City of Sparta are invited to make their needs and preferences known.

Public Involvement

The City of Sparta hosted a public meeting on October 6, 2022 to provide a summary of the transition planning process and receive feedback on any concerns related to accessibility. There were no comments provided at the public meeting. The City will continue to solicit feedback from the public on the Transition Plan.

Facility Evaluations

Amphitheater

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.2 - Accessible Parking Spaces	Create accessible parking spaces.		
Parking	1.3 - Van Accessible Space	Create van accessible space.		
Access	2.12 - Ramp Slope	Reconfigure ramps to decrease slope.		
Access	2.15 - Ramp Handrails	Add handrails.		
Access	2.53 - Wheelchair Space Dispersal	Reconfigure to disperse wheelchair spaces.		
Access	2.61 - Companion Seats	Add companion seats at wheelchair spaces.		
Access	2.76 - Service Counter Accessibility	Lower section of concession counter.		
Access	2.80 - Service Counter Accessibility	Add knee clearaance at lowered section.		
Toilet Rooms	3.5 - Signs at Toilet Rooms	Replace and relocate signs.		
Toilet Rooms	3.7 - Front Approach Clearance	Reconfigure wall at women's room.		
Toilet Rooms	3.19 - Mirror Height	Lower mirrors.		
Toilet Rooms	3.26 - Pipe Insulation	Insulate pipes under lavatories.		
Toilet Rooms	3.34 - Rear Grab Bars	Install rear grab bars.		
Toilet Rooms	3.37 - Flush Control	Move flush control in women's room.		
Toilet Rooms	3.38 - Toilet Paper Dispenser	Relocate toilet paper dipenser in men's room.		
Toilet Rooms	3.45 - Stall Locks	Replace stall locks.		
Additional Access	4.3-4.9 - Drinking Fountain	Replace drinking fountain.		

City Hall

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.3 Van Accessible Space	Create van accessible space.		
Parking	1.11 - Van Accessible Sign	Install van accessible sign.		
Entrance	1.39 - Inaccessible Entrance Sign	Install sign at inaccessible entrance.	\$25	2020
Entrance	1.40 - Accessible Entrance Signs	Install sign at accessible entrance.	\$25	2020
Entrance	1.44 - Door Hardware	Replace locks.	\$300	2020
Entrance	1.49 - Carpet/Mat Securement	Secure edges of mat.		
Access	2.8 - Objects in Circulation Path	Clear circulation path.		
Elevator	2.29 - Car Control Button Signs	Replace car control button signs.		
Elevator	2.31 - Door Jamb Signs	Add tactile star sign on main floor.		
Access	2.38 - Interior Signs	Install tactile signs for permanent rooms.	\$125	2020
Access	2.40 - Door Widths	Alter kitchen door.		
Access	2.43 - Door Hardware	Replace all door hardware.	\$1,600	2020
Access	2.50 - Light Controls	Clear floor space at light controls.		
Access	2.52 - Wheelchair Spaces in Boardroom	Reconfigure to add wheelchair spaces.		
Access	2.76-2.80 - Service Counter	Create accessible section of service counter.	\$1,000	2020
Toilet Rooms	3.x - Accessible Toilet Rooms	Reconfigure toilet rooms.	\$5,000	TBD
Additional Access	4.1 - Drinking Fountain	Remove drinking fountain.		2020

Civic Center

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.2 - Number of Accessible Spaces	Add one more accessible space.	\$200	
Parking	1.10 - Accessible Sign Height	Raise accessible sign height.	\$750	
Parking	1.11 - Van Accessible Signage	Install van accessible sign.	\$25	
Parking	1.28 - Ramp Landing	Expand top ramp landing to 60".	\$7,000	
Parking	1.30 - Ramp Handrails	Install handrails.	\$400	
Entrance	1.41 - Door Opening	Expand door opening.		
Entrance	1.44 - Door Hardware	Replace door hardware.		
Entrance	1.46 - Door Closer	Adjust/replace door closers.		
Entrance	1.49 - Carpets and Mats	Secure edges of entry mats.		
Access	2.8 - Protrusions in Circulation Path	Install tactile warning to drinking fountain and fire extinguisher.	\$500	
Access	2.38 - Signage	Replace interior signs. Adjust height.	\$175	
Access	2.76 - Concession Counter	Install accessible counter.		
Access	2.77 - Concession Counter	Depth.		
Toilet Rooms	3.5 - Signage	Install tactile signs in proper locations.		
Toilet Rooms	3.12 - Door Closer	Adjust/replace door closers.		
Toilet Rooms	3.17 - Clear Floor Space	Create more clear floor space in men's room.		
Toilet Rooms	3.19 - Mirror Height	Lower mirrors in both restrooms.	\$400	
Toilet Rooms	3.20 - Coat Hooks	Adjust height in men's, add hook in women's.	\$50	
Toilet Rooms	3.21 - Clear Floor Space at Lavatory	Alter lavatory in women's.		
Toilet Rooms	3.26 - Lavatory Pipes	Install cover over lavatory pipes.	\$200	
Toilet Rooms	3.27 - Faucet Operation	Replace faucets.	\$1,000	
Toilet Rooms	3.29 - Towel Dispenser	Relocate towel dispensers.		
Toilet Rooms	3.31 - Water Closet	Increase size of accessible stalls.		
Toilet Rooms	3.32 - Toilet Height	Replace women's toilet.		
Toilet Rooms	3.37 - Flush Control	Move toilets?		
Toilet Rooms	3.41 - Stall Door Opening	Widen stall door openings.		
Toilet Rooms	3.43 - Stall Door Closers	Install closers.		
Toilet Rooms	3.45 - Stall Door Locks	Replace locks.		
Toilet Rooms	3.47 - Stall Width	Increase stall width.		
Additional Access	4.6 - Drinking Fountain Height	Lower spout outlet.		

Additional Access

4.9 - Drinking Fountain Protrusion

Install tactile warning.

Dog Pound

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.2 - Accessible Parking Spaces	Create accessible parking spaces.		
Entrance	1.44 - Door Hardware	Replace door hardware.		
Access	2.2 - Accessible Route	Create accessible route to dog pens.		

Electric and Public Works

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.3 - Van Accessible Space	Create van accessible space.	\$400	
Parking	1.11 - Van Accessible Sign	Install van accessible sign.	\$200	
Entrance	1.39 - Inaccessible Entrance Signs	Install signs at inaccessible entrances.	\$50	
Entrance	1.40 - Accessible Entrance Sign	Install sign at accessible entrance.	\$25	
Entrance	1.49 - Carpet/Mat Securement	Secure edges of mat.		
Access	2.8 - Objects in Circulation Path	Clear circulation paths.		
Access	2.38 - Interior Signs	Install signs at permanent rooms.		
Access	2.76 - Accessible Service Counter	Lengthen accessible service counter.		
Toilet Rooms	3.2 - Inaccessible Toilet Room Signs	Install signs at inaccessible toilet rooms.		
Toilet Rooms	3.19 - Mirrors	Lower mirrors.		
Toilet Rooms	3.26 - Pipes Below Lavatory	Insulate pipes.		
Toilet Rooms	3.28 - Soap Dispensers	Lower soap dispenser in women's room.		
Toilet Rooms	3.29 - Towel Dispensers	Lower towel dispensers.		
Toilet Rooms	3.43 - Stall Door Closers	Install closers.		
Toilet Rooms	3.44 - Stall Door Pulls	Install door pulls.		

Farmer's Market

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.5 - Van Accessible Space	Widen van space.	\$200	2020
Parking	1.9 - Aisle Accessible Route	Create accessible route from aisle.		2020
Toilet Rooms	3.5 - Signs	Replace women sign.	\$20	2020
Toilet Rooms	3.29 - Hand Dryer/Towel Dispenser	Adjust dryer/dispenser height.		2020
Toilet Rooms	3.37 - Flush Control	Move womens control.		
Toilet Rooms	3.43 - Door Closers	Add closers.		
Toilet Rooms	3.44 - Door Pulls	Add door pulls.		

Fire Station 1

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.3 - Van Accessible Parking Space	Create van accessible parking space.	\$200	
Parking	1.5 - Van Accessible Parking Space	Create van accessible parking space.		
Parking	1.9 - Access Aisles	Create accessible route at access aisle.		
Parking	1.10 - Accessible Space Sign	Install sign at accessible space.	\$25	
Parking	1.11 - Van Accessible Sign	Install van accessible sign.	\$25	
Entrance	1.39 - Accessible Entrance Sign	Install accessible entrance signs.	\$65	
Entrance	1.40 - Accessible Entrance Sign	Install accessible entrance signs.	\$25	
Entrance	1.44 - Door Hardware	Replace door pull with loop.	\$100	
Entrance	1.45 - Door Hardware	Move hardware to 34"-48".	\$500	
Entrance	1.46 - Door Closer	Adjust closer.		
Entrance	1.49 - Carpet/Mat Attached	Secure mat edges.		
Access	2.2 - All Spaces Accessible	Provide accessible access to upstairs training room.	\$100,000	
Access	2.38 - Signs	Install tactile signs.	\$75	
Access	2.40 - Interior Doors Width	Install offset hinges/alter doorways.		
Access	2.41 - Interior Doors Approach	Remove obstructions/reconfigure walls.		
Access	2.43 - Interior Door Hardware	Replace inaccessible hardware.	\$200	
Access	2.46 - Interior Door Closers	Adjust closers.		
Access	2.49 - Carpet/Mats	Secure mat edges.		
Access	2.51 - Light Switches	Replace light switches.		
Access	2.64 - Dining Surfaces	Alter to provide accessible space.		
Access	2.76 - Service Counter	Alter to provide accessible space.		
Toilet Rooms	3.2 - Signs at Inaccessible Rooms	Add signs to accessible room.		
Toilet Rooms	3.5 - Signs	Alter sign location.		
Toilet Rooms	3.7 - Approach	Remove obstructions/reconfigure walls.		
Toilet Rooms	3.17 - Clear Floor Space	Remove obstructions/reconfigure walls in women's room.		
Toilet Rooms	3.19 - Mirrors	Alter mirror heights.	\$20	
Toilet Rooms	3.20 - Coat Hooks	Alter hook heights.		
Toilet Rooms	3.26 - Lavatory Pipes	Install insulation or cover panel.		
Toilet Rooms	3.28 - Soap Dispensers	Alter dispenser heights in men's and unisex rooms.	\$100	
Toilet Rooms	3.29 - Hand Dryers/Towel Dispensers	Alter dryer/dispenser heights.		

Toilet Rooms	3.31 - Clearance Around Toilet	Alter room/compartment in men's and women's rooms.	
Toilet Rooms	3.32 - Toilet Height	Replace toilet in women's room.	
Toilet Rooms	3.33 - Grab Bar Sizes	Install/relocate bars.	
Toilet Rooms	3.34 - Grab Bars Locations	Install/relocate bars.	
Toilet Rooms	3.41 - Stall Door Width	Widen doors.	
Toilet Rooms	3.42 - Stall Approach	Remove obstructions/reconfigure walls.	
Toilet Rooms	3.43 - Stall Door Closers	Add closers in men's room.	\$100
Toilet Rooms	3.45 - Stall Locks	Replace locks in men's and women's rooms.	
Toilet Rooms	3.47 - Stall Width	Widen stalls in men's and women's rooms.	
Toilet Rooms	3.49 - Stall Depth	Alter stalls in men's and women's rooms.	
Additional Access	4.1 - Drinking Fountain Approach	Alter space.	
Additional Access	4.9 - Drinking Fountain Protusion	Add tactile warning.	

Fire Station - Eastside

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.2 - Accessible Parking Spaces	Create accessible parking spaces.		
Parking	1.3 - Van Parking	Create van accessible parking space.		
Parking	1.7 - Access Aisles	Paint access aisle.		
Parking	1.10-1.11 - Signs	Install accessible and van accessible signs.		
Entrance	1.44 - Door Hardware	Replace door hardware.		
Entrance	1.46 - Door Closer	Adjust closer.		
Access	2.8 - Objects in Circulation Path	Move objects or add tactile warning.		
Access	2.43 - Door Hardware	Replace door hardware.		
Access	2.46 - Door Closers	Adjust closers.		
Toilet Rooms	3.6 - Door Width	Widen door.		
Toilet Rooms	3.12 - Door Closer	Adjust closer.		
Toilet Rooms	3.19 - Mirror	Lower mirror.		
Toilet Rooms	3.26 - Lavatory Pipes	Insulate pipes.		
Toilet Rooms	3.27 - Faucets	Replace faucets.		
Toilet Rooms	3.29 - Towel Dispenser	Lower dispenser.		
Toilet Rooms	3.32 - Toilet Height	Replace toilet.		
Toilet Rooms	3.33-3.34 - Grab Bars	Install grab bars.		
Toilet Rooms	3.37 - Flush Control	Move flush control.		
Toilet Rooms	3.38 - Toilet Paper Dispenser	Relocate dispenser		
Additional Access	4.2 - Drinking Fountain	Replace or remove fountain.		

North Carter Street Park

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.2 - Accessible Parking Spaces	Create accessible parking spaces.		
Access	1.30-1.36 - Handrails	Replace ramp handrails.		
Access	2.64 - Dining Seating	Install accessible picnic table.		

Old City Garage/Press

Not Open to Public

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.2 - Accessible Parking Space	Create accessible parking space.		
Parking	1.3 - Van Accessible Space	Create van accessible parking space.		
Entrance	1.43 - Accessible Entrance (Press)	Install accessible entrance at press building.		
Entrance	1.44 - Door Hardware	Install accessible door hardware.		
Entrance	1.45 - Door Hardware Height	Relocate lock at garage.		
Access	2.38 - Signs	Install tactile signs.		
Toilet Rooms	3.1 - Accessible Restroom	Reconfigure restroom.		
Toilet Rooms	3.18 - Floor Space	Reconfigure restroom.		
Toilet Rooms	3.19 - Mirror	Lower mirror.		
Toilet Rooms	3.20 - Coat Hook	Lower coat hook.		
Toilet Rooms	3.26 - Pipe Insulation	Install pipe insulation under sink.		
Toilet Rooms	3.27 - Faucet Operation	Replace faucet.		
Toilet Rooms	3.28 - Soap Dispenser	Adjust dispenser.		
Toilet Rooms	3.33 - Grab Bars	Install grab bars.		
Toilet Rooms	3.37 - Flush Control	Move control.		
Additional Access	4.6 - Drinking Fountain Height	Adjust drinking fountain.		
Additional Access	4.9 - Drinking Fountain Protrusion	Add tactile warning.		

Oldham Theater

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.3 - Van Accessible Space	Create van accessible parking space.		
Parking	1.5 - Van Accessible Space Width	Widen space for van accessibility.		
Parking	1.11 - Van Accessible Sign	Install van accessible sign.		
Parking	1.12 - Accessible Space Location	Reconfigure spaces closer to entrance.		
Entrance	1.39 - Inaccessible Entrance Sign	Install sign at side door.		
Entrance	1.40 - Accessible Entrance Sign	Install sign at front door.		
Entrance	1.41 - Door Width	Alter front doors.		
Entrance	1.44 - Door Hardware	Replace lock with accessible option.		
Entrance	1.46 - Door Closer	Adjust closers.		
Access	2.38 - Room Signs	Install signs at storage rooms.		
Access	2.50 - Clear Space at Light Switches	Reconfigure control spaces.		
Access	4.8 - Drinking Fountain Height	Raise one drinking fountain.		

Pearson Park

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.11 - Van Accessible Sign	Install van accessible sign.		
Toilet Rooms	3.5 - Signs	Move signs to latch side wall.		
Toilet Rooms	3.9 - Door Hardware	Replace door hardware.		
Toilet Rooms	3.19 - Mirror Height	Lower mirrors.		
Toilet Rooms	3.26 - Lavatory Pipes	Insulate pipes.		
Toilet Rooms	3.37 - Flush Control	Move women's flush control.		
Toilet Rooms	3.38 - Toilet Paper Dispenser	Relocate dispensers.		
Play Area	P9 - Route Width	Widen play area entrance.		

Police Department

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.3 - Van Accessible Space	Create van accessible space.	\$200	
Parking	1.4 - Accessible Space Size	Reconfigure accessible space.		
Parking	1.9 - Accessible Space Route	Reconfigure spaces to create route to door.		
Parking	1.10 - Accessible Space Sign	Install accessible space sign.	\$150	
Parking	1.11 - Van Accessible Sign	Install van accessible sign.		
Parking	1.12 - Accessible Space Close to Entrance	Move accessible space closer to entrance.		
Entrance	1.39 - Inaccessible Entrance Sign	Install inaccessible entrance sign.	\$25	
Entrance	1.40 - Accessible Entrance Sign	Install accessible entrance sign.	\$25	
Entrance	1.41 - Door Width	Alter door opening.		
Entrance	1.44 - Door Hardware	Replace door hardware.	\$200	
Entrance	1.46 - Door Closer	Adjust closers.		
Entrance	1.49 - Carpet/Mat Securement	Secure edges of mat.		
Access	2.8 - Objects in Circulation Path	Clear circulation path.		
Access	2.38 - Interior Signs	Install interior signs at permanent rooms.	\$200	
Access	2.40 - Interior Door Widths	Alter door openings.		
Access	2.41 - Door Approach	Reconfigure walls.	\$3,000	
Access	2.43 - Door Hardware	Replace all door hardware.		
Access	2.46 - Door Closers	Adjust closers.		
Access	2.50 - Light Control Space	Clear space at light controls.		
Access	2.76-2.80 - Service Counter	Install accessible service counter.		
Toilet Rooms	3.2 - Inaccessibe Signs	Install signs at inaccessible rooms.	\$500	
Toilet Rooms	3.3 - Accessible Sign	Install sign accessible room.	\$25	
Toilet Rooms	3.5 - Signs	Replace sign at accessible room.		
Toilet Rooms	3.9 - Door Hardware	Replace door hardware.	\$2,000	
Toilet Rooms	3.29 - Towel Dispenser	Lower towel dispenser.		
Toilet Rooms	3.37 - Flush Control	Move flush control to open side.		
Additional Access	4.1-4.9 - Water Fountain	Replace water fountain.	\$1,500	

Public Works Shop

Not Open to Public

Area	Access Issue	Solution	Cost Estimate	Target Date
Entrance	1.46 - Door Closer	Adjust closer.		
Entrance	1.49 - Carpet/Mat Edges	Secure mat edges.		
Access	2.2 - All Spaces Accessible	Provide accessible access to upstairs offices.		
Access	2.8 - Objects in Circulation Path	Move/remove objects in circulation path.		
Access	2.9 - Elevator	Install elevator/lift or move offices to accessible story.		
Access	2.38 - Signs	Install signs designating rooms and spaces.	\$140	
Access	2.42 - Interior Door Thresholds	Remove or replace thresholds.	\$1,500	
Access	2.43 - Door Hardware	Replaces inaccessible knobs.	\$800	
Access	2.50 - Light Switches	Clear appropriate floor spaces at controls.		
Toilet Rooms	3.1 - Accessible Toilet Room	Reconfigure toilet room to be accessible.		
Additional Access	4.1 - Drinking Fountain Space	Alter drinking fountain space or relocate fountain.		

Senior Center

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.7 - Access Aisle	Paint access aisle.	\$200	
Parking	1.10 - Sign Height	Raise accessible signs.	\$300	
Parking	1.11 - Van Accessible Sign	Install van accessible sign.	With above	
Entrance	1.39 - Sign at Inaccessible Entrance	Install sign at inaccessible entrance.	\$25	
Entrance	1.40 - Sign at Accessible Entrance	Install sign at accessible entrance.	\$200	
Entrance	1.44 - Door Hardware	Replace lock.	\$100	
Entrance	1.49 - Carpets/Mats	Secure edges of mat.		
Access	2.8 - Objects in Circulation Path	Rearrange objects/add tactile warning.	\$400	
Access	2.38 - Signs	Install tactile signs.	\$100	
Toilet Rooms	3.5 - Signs	Install tactile signs.	With above	
Toilet Rooms	3.20 - Coat Hooks	Lower coat hooks.	\$75	
Toilet Rooms	3.34 - Rear Grab Bars	Replace rear grab bars.	\$800	
Toilet Rooms	3.43 - Door Closers	Install closers on accessible stalls.		
Additional Access	4.2 - Drinking Fountain Approach	Replace drinking fountain.	\$1,500	
Additional Access	4.6 - Drinking Fountain Height	Replace drinking fountain.		
Additional Access	4.7 - Drinking Fountain Spout	Replace drinking fountain.		
Additional Access	4.9 - Drinking Fountain Protrusion	Add tactile warning.	\$100	
Additional Access	4.14 - Phone Volume Control	Replace with phone with accessible features.		
Additional Access	4.15 - Phone TTY	Replace with phone with accessible features.		

Skate Park

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.2 - Accessible Parking	Create accessible parking space.		
Parking	1.3 - Van Accessible Space	Create van accessible parking space.		
Parking	1.10 - Signs	Install accessible parking signs.		

South Carter Street Park

Area	Access Issue	Solution	Cost Estimate	Target Date
Approach	1.17 - Slope	Regrade path from parking lot to flat area.		
Approach	1.18 - Cross Slope	Regrade path from parking lot to flat area.		
Approach	1.31 - Handrail Height	Lower handrail.		
Approach	1.34 - Handrail Gripping Surface	Replace handrail top.		
Approach	1.35 - Handrail Extension	Alter handrail.		
Approach	1.36 - Handrail Barrier	Add bottom handrail barrier.		
Entrance	1.40 - Accessible Sign	Install accessible sign at pavilion ramp.		
Access	2.64 - Accessible Dining	Add accessible picnic tables.		
Toilet Rooms	3.10 - Door Hardware Height	Lower inside door hardware.		
Toilet Rooms	3.26 - Lavatory Pipes	Insulate pipes.		
Toilet Rooms	3.30 - Water Closet Distance	Move toilet closer to wall.		
Toilet Rooms	3.32 - Water Closet Height	Replace toilet.		
Toilet Rooms	3.33 - Side Grab Bar Length	Replace side grab bars.		
Toilet Rooms	3.37 - Flush Control	Move men's flush control.		
Toilet Rooms	3.38 - Toilet Paper Dispenser	Relocate dispensers.		
Play Area	P1 - Accessible Entrance	Regrade entrance to small play area.		
Play Area	P9 - Route Width	Widen entrance path at large play area.		
Play Area	P10 - Route Slope	Regrade entrance to small play area.		

South Church Street Pavilion

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.2 - Accessible Parking Spaces	Create accessible parking spaces.		
Parking	1.9 - Accessible Route	Paint aisle from parking to pavilion.		
Access	1.43 - Threshold	Bevel lip at pavilion entrance.		

Wallace - Smith Park

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.3 - Van Accessible Parking Space	Create van accessible parking space.	\$200	2020
Parking	1.4 - Accessible Space Aisle	Create 5' aisle at accessible space.	With above	
Parking	1.5 - Van Accessible Parking Space	Create van accessible parking space.	With above	
Parking	1.11 - Van Accessible Signage	Install van accessible sign.	\$25	
Approach	1.31 - Handrail Height	Adjust handrail height.		
Approach	1.36 - Handrail Lowe Barrier	Add lower barrier.		
Approach	1.39 - Accessible Route Signage	Add accessible route signs.		
Seating at Dining Surfaces	2.67 - Clear Floor Space	Add accessible picnic table.	\$1,500	
Toilet Rooms	3.8 - Threshold Height	Bevel concrete thresholds.		
Toilet Rooms	3.26 - Lavatory Pipes	Install cover over lavatory pipes.	Complete	
Toilet Rooms	3.27 - Faucet Operation	Replace faucets.	Complete	
Toilet Rooms	3.32 - Toilet Height	Replace men's toilet.	Complete	
Toilet Rooms	3.33 - Grab Bars	Install longer side grab bars.	Complete	
Toilet Rooms	3.34 - Grab Bars	Install rear grab bars.	Complete	
Toilet Rooms	3.37 - Flush Control	Move men's flush control to open side.	Complete	

Wastewater Treatment Plant

Not Open to Public

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.2 - Accessible Parking Spaces	Create accessible parking spaces.		
Parking	1.3 Van Accessible Parking	Create van accessible parking spaces.		
Parking	1.10 - Signs	Install accessible space signs.		
Entrance	1.44 - Door Hardware	Replace door hardware.		
Entrance	1.46 - Door Closer	Adjust closer.		
Entrance	1.49 - Carpet/Mat Securement	Secure edges of mat.		
Access	2.8 - Objects in Circulation Path	Add tactile warning to fire extinguisher.		
Access	2.40 - Interior Door Width	Widen doors.		
Access	2.43 - Door Hardware	Replace door hardware.		
Access	2.46 - Door Closers	Adjust closers.		
Access	2.50 - Light Switches	Clear area around switches.		
Toilet Rooms	3.5 - Signs	Move sign to latch side wall.		
Toilet Rooms	3.12 - Door Closer	Adjust closer.		
Toilet Rooms	3.19 - Mirror	Lower mirror.		
Toilet Rooms	3.20 - Coat Hook	Lower coat hook.		
Toilet Rooms	3.26 - Lavatory Pipes	Insulate pipes.		
Toilet Rooms	3.29 - Towel Dispenser	Lower dispenser.		
Toilet Rooms	3.50 - Stall Width	Widen stall.		
Additional Access	4.2 - Drinking Fountain	Replace drinking fountain.		

Water Treatment Plant

Not Open to Public

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.2 - Accessible Parking Spaces	Create accessible parking spaces.		
Access	2.x - Access to Spaces	Install elevator or lift to all levels.		
Access	2.43 - Door Hardware	Replace door hardware.		
Access	2.47 - Door Closers	Adjust closers.		
Toilet Rooms	3.x - Accessible Restroom	Reconfigure toilet room and install signs.		
Additional Access	4.x - Drinking Fountain	Replace drinking fountain.		

YMCA

Area	Access Issue	Solution	Cost Estimate	Target Date
Parking	1.5 - Van Accessible Space	Widen van space.	\$200	
Parking	1.11 - Van Accessible Sign	Install van accessible sign.	\$25	
Curb Ramps	1.20 - Curb Ramp Slope	Regrade curb ramp.	\$500	
Curb Ramps	1.23 - Curb Ramp Landing	Install curb ramp landing or see 1.24.	With above	
Curb Ramps	1.24 - Curb Ramp Flares	Regrade flares.	With above	
Entrance	1.44 - Door Hardware	Replace door hardware.	\$200	
Entrance	1.46 - Door Closer	Adjust closers.		
Entrance	1.47 - Vestibule Clearance	Remove inner doors or change swing.		
Entrance	1.49 - Carpets/Mats	Secure edges of mat.		
Access	2.2 - Areas Accessible on One Route	Create accessible routes to gym and concessions.	\$25,000	
Access	2.8 - Circulation Path Protrusions	Add tactile warning at coat rack.	\$1,000	
Access	2.38 - Signs	Add tactile signs.	\$75	
Access	2.40 - Door Openings	Alter office doorway.		
Access	2.43 - Door Hardware	Replace door hardware.	\$100	
Access	2.52 - Assembly Areas	Add wheelchair spaces in gym.	\$1,000	
Toilet Rooms	3.2 - Signs at Inaccessible Rooms	Install signs.	\$100	
Toilet Rooms	3.3 - Signs at Accessible Rooms	Install signs.	With above	
Toilet Rooms	3.5 - Signs at Toilet Rooms	Install signs.	With above	
Toilet Rooms	3.9 - Door Hardware	Replace door hardware in gym.		
Toilet Rooms	3.19 - Mirrors	Lower mirrors.		
Toilet Rooms	3.20 - Coat Hooks	Adjust coat hook in gym.		
Toilet Rooms	3.22 - Under Lavatory Space	Replace lavatory in gym.	\$750	
Toilet Rooms	3.24 - Under Lavatory Clearance	Replace lavatory in gym.		
Toilet Rooms	3.26 - Lavatory Pipe Insulation	Install insulation.	\$75	
Toilet Rooms	3.27 - Faucets	Replace faucet in gym.	\$100	
Toilet Rooms	3.28 - Soap Dispenser Heights	Adjust dispensers.		
Toilet Rooms	3.29 - Hand Dryers/Towel Dispenser Heights	Adjust dryers/dispensers.		
Toilet Rooms	3.31 - Water Closet Clearance	Alter room/stalls for clearance.		
Toilet Rooms	3.32 - Toilet Height	Replace toilets.	\$400	
Toilet Rooms	3.33 - Grab Bars	Relocate/install grab bars.		

Toilet Rooms	3.34 - Grab Bars Rear	Relocate/install grab bars.
Toilet Rooms	3.37 - Flush Controls	Move controls.
Toilet Rooms	3.47 - Compartment Widths	Widen compartments.
Toilet Rooms	3.49 - Compartment Depths	Alter compartments.
Additional Access	4.6 - Drinking Fountain Height	Adjust or replace fountain.
Pool	P68 - Handrail Width	Relocate handrails.
Pool	P70 - Handrail Extensions	Add extensions.

Street Intersections

Street Intersection ADA Status

Street	Cross Street	Status
Allen Dr	Brown St	No Sidewalk
Allen Dr	Breeding Dr	No Sidewalk
Allen Dr	Roosevelt Dr	No Ramps/No Tactile Surface
Anderson St	Marshall St	No Ramps/No Tactile Surface
Baker St	Selby St	No Sidewalk
Baker St	Marty Stuart Dr	No Sidewalk
Baker St	Flatt St	No Ramps/No Tactile Surface
Baker St	Walker St	No Ramps/No Tactile Surface
Beecher Farley Rd	Choff Ln	No Sidewalk
Ben Lomand Dr	Terrace Dr	No Sidewalk
Ben Lomand Dr	Hampton Dr	No Ramps/No Tactile Surface
Ben Lomand Dr	Cook St	No Sidewalk
Breeding Dr	Moore St	No Sidewalk
Brown St	Riverview Dr	No Sidewalk
Burley St	Davis St	Ramps/No Tactile Surface
Carson St	Knowles St	No Sidewalk
Cedar Ln	Terrace Dr	No Sidewalk
Cedar Ln	Hampton Dr	No Sidewalk
Cedar Ln	Pearson St	No Sidewalk
Churchill Dr	Ben Lomand Dr	No Sidewalk
Churchill Dr	Cedar Ln	No Sidewalk
Churchill Dr	Norcom Way	No Sidewalk
Clark St	West St	No Ramps/No Tactile Surface
Clark St	Depot St	No Ramps/No Tactile Surface
Clarks Mill Dr	Masonic Dr	No Sidewalk
Cliffview Dr	Mountain View Dr	No Sidewalk
Cliffview Dr	Hillview Dr	No Sidewalk
Cooper St	Ellis Cir	No Sidewalk
Cooper St	Dales Pl	No Sidewalk
Crescent St	Madison Ave	No Sidewalk

Street	Cross Street	Status
Depot St	Unnamed Alley	No Ramps/No Tactile Surface
Dibrell St	Clark St	Ramps/Tactile Surface
Dibrell St	Katz St	No Sidewalk
Dibrell St	IMix Dr	No Sidewalk
Dibrell St	Carson St	No Sidewalk
E Bronson St	Pleasant St	No Sidewalk
E Bronson St	Willis St	No Sidewalk
E Bronson St	Sparkman St	No Sidewalk
E Bronson St	Wagoner St	No Sidewalk
E Bronson St	Farris St	No Sidewalk
E Bronson St	Baker St	No Sidewalk
E Bronson St	Oakwood St	Ramps/No Tactile Surface
E Charlene Dr	Crosslin St	No Sidewalk
E College St	Quill E Cope St	No Ramps/No Tactile Surface
E Everett St	Anderson St	No Ramps/No Tactile Surface
E Everett St	E Bronson St	No Ramps/No Tactile Surface
E Maple St	Liberty Sq W	Ramps/No Tactile Surface
E Maple St	Liberty Sq (E)	Ramps/No Tactile Surface
E Maple St	S Young St	Ramps/Tactile Surface
E Maple St	S Butler St	No Ramps/No Tactile Surface
E Maple St	Greenlawn Dr/Gaines St	No Ramps/No Tactile Surface
E Rhea St	Marchbanks St	No Sidewalk
Ellis Cir	Sherrell St	No Sidewalk
Emma L Officer Dr	King St	No Sidewalk
Flatt St	N Harris St	No Sidewalk
Flatt St	Clay Ln	No Sidewalk
Flatt St	Luther Rd	No Sidewalk
Freedom Tr	Nob Hill Dr	No Sidewalk
Freedom Tr	Sharon Cir	No Sidewalk
Freedom Tr	Jackson Blvd	No Sidewalk
Gaines St	S Gracey St	No Ramps/No Tactile Surface
Gaines St	Stamps St	No Sidewalk
Gaines St	Dr Gaines St	No Ramps/No Tactile Surface

Street	Cross Street	Status
Gaines St	Highland Dr	No Ramps/No Tactile Surface
Gaines St	S Harris St	No Ramps/No Tactile Surface
Gaines St	Oak St	No Ramps/No Tactile Surface
Gaines St	Hillcrest Dr	Ramps/No Tactile Surface
Gaines St	Quarry St	Ramps/No Tactile Surface
Geer St	Ruby Dr	No Sidewalk
Gillen Dr	North St	No Sidewalk
Gillen Dr	Foxwood Ln	No Sidewalk
Gillen Dr	Morningside Dr	No Sidewalk
Gillen Dr	Freedom Tr	No Sidewalk
Gillen Dr	Mockingbird Dr	No Sidewalk
Golden Mountain Rd	Hale St	No Sidewalk
Gracey St	Geer St	No Ramps/No Tactile Surface
Hale St	Turn Table Rd	No Sidewalk
Hale St	Sidney Ln	No Sidewalk
Hampton Dr	Polk St	No Sidewalk
Hayes St	Unnamed Alley	No Ramps/No Tactile Surface
Hayes St	Clark St	No Ramps/No Tactile Surface
Hayes St	Simmerell St	No Ramps/No Tactile Surface
Hillview Dr	Story Dr	No Sidewalk
Jay Scott Ln	Wanda Ln	No Sidewalk
Kent St	Randles St	No Sidewalk
Lee St	Project Dr	No Ramps/No Tactile Surface
Lum St	Virginia Ave	No Sidewalk
Luther Rd	Walker St	No Sidewalk
Madison Ave	Greenwood Dr	No Sidewalk
Masonic Dr	Cope St	No Sidewalk
Moore St	McDole St	No Ramps/No Tactile Surface
Moore St	Ben Lomand Dr	No Ramps/No Tactile Surface
Moore St	Grissom St	No Ramps/No Tactile Surface
Moore St	Polk St	No Ramps/No Tactile Surface
Moore St	Brown St	No Ramps/No Tactile Surface
Mose Dr	Shelton St	No Sidewalk

Street	Cross Street	Status
N Butler St	E Rhea St	No Ramps/No Tactile Surface
N Butler St	Gracey Hts	No Ramps/No Tactile Surface
N Camp Hts	A St	No Sidewalk
N Camp Hts	B St	No Sidewalk
N Carter St	Roberts St/Riverside Dr	No Sidewalk
N Church St	W Everett St	Ramps/No Tactile Surface
N Church St	W Rhea St	Ramps/No Tactile Surface
N Church St	W College St	Ramps/No Tactile Surface
N Church St	Nassau St	Ramps/No Tactile Surface
N Edgewood Dr	Volunteer Dr	No Sidewalk
N Edgewood Dr	Hutchings St	No Sidewalk
N Oak St	Dogwood St	No Sidewalk
N Wilson St	King St (S)	No Sidewalk
N Wilson St	King St (N)	No Sidewalk
Nob Hill Dr	Unnamed Alley	No Sidewalk
Oakland Dr	North Ave	No Sidewalk
Oakland Dr	Morningside Dr	No Sidewalk
Oakland Dr	Freedom Tr	No Sidewalk
Oakland Dr	Deer Circle Dr	No Sidewalk
Oakland Dr	Sunrise Ridge Dr	No Sidewalk
Oakwood St	Burton Rd	No Ramps/No Tactile Surface
Oakwood St	Officer Dr	No Sidewalk
Old Smithville Hwy N	Mose Dr	No Sidewalk
Old Smithville Hwy N	Kinnard Rd	No Sidewalk
Pleasant St	Swindell St	No Sidewalk
Polk St	Allen Dr	No Sidewalk
Polk St	Pearson St	No Sidewalk
Poplar St	Sparkman St	No Sidewalk
Quill E Cope St	Anderson St	No Ramps/No Tactile Surface
Quill E Cope St	E Bronson St	No Ramps/No Tactile Surface
Roberts St	Emma L Officer Dr/Riverside Dr	No Sidewalk
Roosevelt Dr	Robert Knight Dr	Ramps/No Tactile Surface
Roosevelt Dr	Churchill Dr/Sewell Dr	No Sidewalk

Street	Cross Street	Status
Roosevelt Dr	State St	No Sidewalk
Roosevelt Dr	Mose Dr (E)	No Sidewalk
Roosevelt Dr	Mose Dr (W)	No Sidewalk
S Camp Hts	A St	No Sidewalk
S Camp Hts	B St	No Sidewalk
S Carter St	Katz St	No Ramps/No Tactile Surface
S Carter St	Carson St	No Ramps/No Tactile Surface
S Carter St	Templeton St	No Ramps/No Tactile Surface
S Church St	W Maple St	No Ramps/No Tactile Surface
S Church St	W Wall St	No Ramps/No Tactile Surface
S Church St	Cedar Bend St	No Sidewalk
S Church St	Walnut Dr	No Sidewalk
S Edgewood Dr	Hutchings St	No Sidewalk
S Edgewood Dr	Volunteer Dr	No Sidewalk
S Highland Dr	Ellis Cir	No Ramps/No Tactile Surface
S Main St	Cedar Bend St	No Ramps/No Tactile Surface
S Main St	Wall St	No Ramps/No Tactile Surface
S Oak St	Cooper St	No Sidewalk
S Spring St	Clark St	Ramps/No Tactile Surface
S Spring St	Simmerell St	No Ramps/No Tactile Surface
S Spring St	Love St	No Ramps/No Tactile Surface
S Spring St	Town Creek St	No Ramps/No Tactile Surface
S Wilson St	Depot St	Ramps/No Tactile Surface
S Wilson St	IMix Dr	No Ramps/No Tactile Surface
S Wilson St	Clark St	Ramps/No Tactile Surface
S Young St	E Wall St	Ramps/Tactile Surface
S Young St	Hickey Dr	Ramps/Tactile Surface
S Young St	Sims St	Ramps/Tactile Surface
S Young St	S Main St	Ramps/Tactile Surface
S Young St	Mitchell St	No Ramps/No Tactile Surface
S Young St	Lee St	No Ramps/No Tactile Surface
S Young St	Kent St	Ramps/No Tactile Surface
S Young St	N Camp Hts	Ramps/Tactile Surface

Street	Cross Street	Status
S Young St	S Camp Hts	Ramps/No Tactile Surface
S Young St	Windsor Dr	No Sidewalk
S Young St	Winding Ln	No Sidewalk
S Young St	Sugar Hill Dr	No Sidewalk
S Young St	Hargis Ln	No Sidewalk
Saylors St	Scott Ln	Ramps/No Tactile Surface
Selby St	Geer St	No Sidewalk
Selby St	Jachin St	No Sidewalk
Sewell Dr	W Turn Table Rd	No Sidewalk
Sidney Ln	Meadowbrook Dr	No Sidewalk
Simmerell St	Depot St	No Sidewalk
Sparkman St	Virginia Ave	No Sidewalk
Sparkman St	Helen Pl	No Sidewalk
Sparkman St	Lum St	No Sidewalk
State St	Norcom Way	No Sidewalk
Sugar Hill Dr	Hillview Dr	No Sidewalk
Swindell St	Anderson St	No Sidewalk
Templeton St	Knowles St	No Sidewalk
Terrace Dr	Polk St	No Sidewalk
Thompson Dr	Industrial Dr/Auto Ln	No Sidewalk
Thompson Weiman Rd	Hillcrest Dr	No Sidewalk
Thompson Weiman Rd	Quarry St	No Sidewalk
Town Creek St	Love St	No Sidewalk
Turn Table Rd	Meadowbrook Dr	No Sidewalk
Turn Table Rd	Woodlawn Dr	No Sidewalk
Turn Table Rd	Crescent St	No Sidewalk
Turn Table Rd	Greenwood Dr	No Sidewalk
Turn Table Rd	Beecher Farley Rd	No Sidewalk
Turn Table Rd	Burley St	No Sidewalk
Turn Table Rd	Oak Forest Ln	No Sidewalk
Turn Table Rd	Ray Broyles Rd	No Sidewalk
Valley View Dr	Mose Dr	No Sidewalk
Virginia Ave	Helen Pl	No Sidewalk

Street	Cross Street	Status
Vista Dr	Chester Dr	No Sidewalk
W Bronson St	Boyd St	No Sidewalk
W Charlene Dr	Crosslin St	No Sidewalk
W Everett St	Boyd St	No Sidewalk
W Everett St	Saylors St	No Ramps/No Tactile Surface
W Maple St	Liberty Sq	Ramps/No Tactile Surface
W Maple St	S Main St	Ramps/No Tactile Surface
W Turn Table Rd	Allen Dr	No Sidewalk
Wagoner St	Hellen Pl	No Sidewalk
Wagoner St	Cave St	No Sidewalk
Wagoner St	Lum St	No Sidewalk
Wagoner St	Poplar St	No Sidewalk
Walker Cove Rd	E Charlene Dr	No Sidewalk
Walker Cove Rd	W Charlene Dr	No Sidewalk
Walker Cove Rd	Maughon Dr	No Sidewalk
Walker St	Old School Driveway	No Ramps/No Tactile Surface
Walker St	Selby St	No Sidewalk
Walker St	Willis St	No Sidewalk
Walker St	Farris St	No Sidewalk
West St	Unnamed Alley	No Ramps/No Tactile Surface
Winding Ln	Cumberland St	No Sidewalk
Winding Ln	Whispering Pines Dr	No Sidewalk
Winding Ln	Randles St	No Sidewalk
Windsor Dr	Dales Pl	No Sidewalk
Windsor Dr	Hillview Dr	No Sidewalk
Windsor Dr	Mountain View Dr	No Sidewalk
Windsor Dr	Leon Dr	No Sidewalk
Woodlawn Dr	Crescent St	No Sidewalk
Woodlawn Dr	Sidney Ln	No Sidewalk