

CITY OF SPARTA, TN  
SEWER USE ORDINANCE  
INDUSTRIAL USER DISCHARGE  
LIMITS 2023

PARAMETER	MORE STRINGENT		
	NON CATEGORICAL	CATEGORICAL	
	LIMITS	LIMITS	
		FOR METAL FINISHER CATEGORY	
	MONTHLY AVERAGE	DAILY MAX	MONTHLY AVERAGE
	mg/L	mg/L	mg/l
Copper	10.400	3.380	2.070
Chromium III	report only		
Chromium IV	4.470		
Chromium, Total	5.901	2.770	1.710
Nickel	5.550	3.980	2.380
Cadmium	0.248	0.690	*0.248
Lead	1.500	0.690	0.430
Mercury	0.006		
Silver	0.283	0.430	0.240
Zinc	10.842	2.610	1.480
Cyanide	0.334		
Toluene	1.710		
Benzene	0.113		
1,1,1 Trichloroethane	1.600		
Ethylbenzene	0.222		
Carbon Tetrachloride	0.309		
Chloroform	2.030		
Tetrachloroethylene	0.995		
Trichloroethylene	0.721		
1,2 Transdichloroethylene	0.029		
Methylene Chloride	1.020		
Total Phenols	3.460		
Naphthalene	0.029		
Total Phthalates	1.270		
TTO's		2.13	
BOD	800		
TSS	800		
Oils and Grease	300		
pH limit range	5.5 - 9.5		

\* Local Limit is lower than the categorical limit, so local limit applies.